

**TOWN OF EAST BLOOMFIELD
CODE ENFORCEMENT OFFICE**

SEPTIC SYSTEM PERMIT

PERMIT #: _____ DATE: _____

NAME: _____

ADDRESS: _____

PHONE #: _____

DESCRIPTION OF WORK: _____

CONTRACTORS NAME: _____

ADDRESS: _____

PHONE #: _____

PLOT PLAN WILL BE ATTACHED SHOWING EXISTING SYSTEM, SEPTIC TANK, LEACH FIELD DIAGRAM, DROP BOXES AND WILL ALSO SHOW CHANGES BEING MADE. THIS PERMIT IS SUBJECT TO APPROVAL AND INSPECTION BY THE CODE ENFORCEMENT OFFICER.

FEE: \$ _____

APPLICANT SIGNATURE

_____ approval

_____ disapproval

CODE ENFORCEMENT OFFICER

Town of East Bloomfield Septic Law

Town, Village of: _____			
Owner name: _____		Street address: _____	
Tax map #: _____			
Date of inspection: _____			
Most recent date tank pumped: _____			
Name of Contractor/Waste hauler: _____			
Indicate type of Inspection: _____ Change of Use _____ Conveyance of Real Property _____ Expansion greater than Fifty Percent (50%) _____ Complaint _____ Other, Specify: _____			
1	Is any part of the septic system less than 100 feet from a well, pond, stream, lake or other watercourse? If yes, indicate distance separations:	No	Yes
2	Is there any evidence of surface discharge of effluent visible in the general location of the leach bed area? If yes, explain:	No	Yes
3	Is there any evidence of standing water, odor of effluent, or soft ground apparent in the general location of the leach bed area? If yes, explain:	No	Yes
4	Is there any evidence that may indicate effluent is being improperly discharged into road ditches, drainage tiles or other improper locations? If yes, explain:	No	Yes
5	Do existing contours direct water away from the leach bed area?	No	Yes
6	Is there a watertight vessel?	No	Yes
7	Is the size and condition of the septic tank suitable for the number of bedrooms in the existing dwelling? Indicate size of tank _____ # of bedrooms _____ Type of tank: Concrete _____ Metal _____ Other _____	No	Yes
8	Are septic tank baffles in place and functioning properly?	No	Yes
9	Is the distribution box or system in good physical condition?	No	Yes
10	Are outlet pipes clear of solids or other blockages?		
11	Does effluent appear to be discharged equally within the leach bed area and not limited to the ends of the laterals or other individual areas?	No	Yes
12	Do toilets flush efficiently without backing up or flushing slowly?	No	Yes
13	Is the plumbing system provided with a building vent?	No	Yes
Decision: _____ System appears to be adequately functioning and maintained as required _____ System does not appear to be adequately functioning and maintained as required			
Remarks: _____			
Signature: _____			